

Impact Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-502
Company Code:	190
Certification Date:	1/20/2015
Revision No:	1
Revision Date:	1/28/2025
Expiration Date:	1/12/2028

Product Rating Information:

Model:	AW5540 PVC Impa	ct Awning		
Operator Type:	AP			
Configuration:	All/Snub, GS-5/16"	Ann Lami IG		
Referenced Standard:	ASTM E1886-19/E1	996-23		
Product Rating:	Missile Level D, Wir	nd Zone 4, DP=+/-50), 60x42	
Rated Dimensions:	Max Width:	60 in	Max Height:	42 in
Linked Structural CARs:	190-1065.0			

Qualifying Test information:

Test Report No:	FTL-8149/8150/8151
Test Report Expiration:	1/12/2028

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull Shaun Shaull 2025.01.28 11:27:23 -05'00'

Keystone Certifications, Inc. 145 Limekiln Rd. Suite 100B New Cumberland, PA 17070 Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

0 1/20/2015 Initial issuance. 1 1/28/2025 Granted 3 year extension. Updated reference standard year due to standard equivalency.	Rev#	Date	Description
1 1/28/2025 Granted 3 year extension. Updated reference standard year due to standard equivalency.	0	1/20/2015	Initial issuance.
	1	1/28/2025	Granted 3 year extension. Updated reference standard year due to standard equivalency.

Doc No: FRM B1-43 Rev No: 6 Rev Date: 8/30/2022 <u>www.keystonecerts.com</u> Page **2** of **2**



Impact Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-503
Company Code:	190
Certification Date:	1/20/2015
Revision No:	1
Revision Date:	1/28/2025
Expiration Date:	1/13/2028

Product Rating Information:

Model:	AW5540 PVC Impac	ct Awning		
Operator Type:	AP			
Configuration:	All/Snub, GS-5/16"	Ann Lami IG		
Referenced Standard:	ASTM E1886-19/E1	996-23		
Product Rating:	Missile Level D, Wir	nd Zone 4, DP=+65/-	-70, 52x42	
Rated Dimensions:	Max Width:	52 in	Max Height:	42 in
Linked Structural CARs:	190-1066.0			

Qualifying Test information:

Test Report No:	FTL-8153/8154
Test Report Expiration:	1/13/2028

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull Shaun Shaul 2025.01.28 11:29:03 -05'00'

Keystone Certifications, Inc. 145 Limekiln Rd. Suite 100B New Cumberland, PA 17070 Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

0 1/20/2015 Initial issuance. 1 1/28/2025 Granted 3 year extension. Updated reference standard year due to standard equivalency.	Rev#	Date	Description
1 1/28/2025 Granted 3 year extension. Updated reference standard year due to standard equivalency.	0	1/20/2015	Initial issuance.
	1	1/28/2025	Granted 3 year extension. Updated reference standard year due to standard equivalency.

Doc No: FRM B1-43 Rev No: 6 Rev Date: 8/30/2022 <u>www.keystonecerts.com</u> Page **2** of **2**



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr N. Venice, FL 34275, USA

Certification ID:	190-1065
Company Code:	190
Certification Date:	1/19/2015
Revision No:	1
Revision Date:	1/28/2025
Expiration Date:	1/12/2028

Product Rating Information:

Model:	AW5540 PVC Impac	ct Awning		
Operator Type:	AP			
Configuration:	All/Snub, GS-5/16"	Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA	101/IS2/A440-22		
Product Rating:	Class LC-PG50 1524x1067 (60x42)-Type AP WTP=9.75			
Rated Dimensions:	Max Width:	60 in	Max Height:	42 in

Qualifying Test Information:

Test Report No:	FTL-8148
Test Report Expiration:	1/12/2028

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull Shaun Shaull 2025.01.28 11:01:37 -05'00'

Keystone Certifications, Inc. 145 Limekiln Rd, Suite 100B New Cumberland, PA 17070 Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev#	Date	Description
0	1/19/2015	Initial issuance.
1		Granted 3 year extension. Updated reference standard year to 2022 due to standard equivalency.

Doc No: FRM B1-02 Rev No: 10 Rev Date 8/30/2022 <u>www.keystonecerts.com</u> Page 2 of 2



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr N. Venice, FL 34275, USA

Certification ID:	190-1066
Company Code:	190
Certification Date:	1/20/2015
Revision No:	1
Revision Date:	1/28/2025
Expiration Date:	1/13/2028

Product Rating Information:

Model:	AW5540 PVC Impact Awning				
Operator Type:	АР				
Configuration:	All/Snub, GS-5/16" Ann Lami IG				
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-22				
Product Rating:	Class LC-PG65 1324x1067 (52x42)-Type AP Neg DP=70				
Rated Dimensions:	Max Width:	52 in	Max Height:	42 in	

Qualifying Test Information:

Test Report No:	FTL-8152
Test Report Expiration:	1/13/2028

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull Shaun Shaull 2025.01.28 11:15:46 -05'00' Keystone Certifications, Inc. 145 Limekiln Rd, Suite 100B New Cumberland, PA 17070 Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev#	Date	Description
0	1/20/2015	Initial issuance.
1	1/28/2025	Granted 3 year extension. Updated reference standard year to 2022 due to standard equivalency.

Doc No: FRM B1-02 Rev No: 10 Rev Date 8/30/2022 <u>www.keystonecerts.com</u> Page 2 of 2