



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

Certification ID:	190-1057
Company Code:	190
Certification Date:	1/16/2015
Revision No:	1
Revision Date:	1/28/2025
Expiration Date:	1/9/2028

Product Rating Information:

Model:	CA5440 PVC Casement			
Operator Type:	C			
Configuration:	All/Snub			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11			
Product Rating:	Class LC-PG50 914x1905 (36x75)-Type C			
Rated Dimensions:	Max Width:	36 in	Max Height:	75 in

Qualifying Test Information:

Test Report No:	FTL-8077
Test Report Expiration:	1/9/2028

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2025.01.28 09:53:27
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

Certification ID:	190-1058
Company Code:	190
Certification Date:	1/16/2015
Revision No:	1
Revision Date:	1/28/2025
Expiration Date:	1/9/2028

Product Rating Information:

Model:	CA5440 PVC Casement			
Operator Type:	C			
Configuration:	All/Snub			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11			
Product Rating:	Class LC-PG65 1016x2134 (40x84)-Type C Neg DP=70			
Rated Dimensions:	Max Width:	40 in	Max Height:	84 in

Qualifying Test Information:

Test Report No:	FTL-8079
Test Report Expiration:	1/9/2028

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2025.01.28 09:51:35
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

Certification ID:	190-1059
Company Code:	190
Certification Date:	1/16/2015
Revision No:	1
Revision Date:	1/28/2025
Expiration Date:	1/9/2028

Product Rating Information:

Model:	CA5540 PVC Impact Casement			
Operator Type:	C			
Configuration:	All/Snub, GS-5/16" Ann Lami IG			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11			
Product Rating:	Class LC-PG50 914x1905 (36x75)-Type C WTP=9.75			
Rated Dimensions:	Max Width:	36 in	Max Height:	75 in

Qualifying Test Information:

Test Report No:	FTL-8081
Test Report Expiration:	1/9/2028

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2025.01.28 09:58:39
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

Certification ID:	190-1060
Company Code:	190
Certification Date:	1/16/2015
Revision No:	1
Revision Date:	1/28/2025
Expiration Date:	1/9/2028

Product Rating Information:

Model:	CA5540 PVC Impact Casement			
Operator Type:	C			
Configuration:	All/Snub, GS-5/16" Ann Lami IG			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11			
Product Rating:	Class LC-PG65 914x2134 (36x84)-Type C Neg DP=70			
Rated Dimensions:	Max Width:	36 in	Max Height:	84 in

Qualifying Test Information:

Test Report No:	FTL-8083
Test Report Expiration:	1/9/2028

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull Shaun Shaull
2025.01.28 10:00:20
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Industries, Inc.

1070 Technology Dr.
N. Venice, FL 34275, USA

Certification ID:	190-1350
Company Code:	190
Certification Date:	10/11/2023
Revision:	0
Revision Date:	10/11/2023
Expiration Date:	10/11/2027

Product Rating Information:

Model:	CA5440 PVC Casement Window			
Operator Type:	C			
Configuration:	ALL/SNUB, GS - 1/8" Ann IG			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-22			
Product Rating:	Class LC-PG35 914x1905 (~36x75)-Type C			
Rated Dimensions:	Max Width:	36 in	Max Height:	75 in

Qualifying Test Information:

Test Report No:	NOK-0046
Test Report Expiration:	10/11/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standards. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of certification labels for the Keystone Fenestration Certification Program. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.



Authorized By:

Shaun Shaul
Shaun Shaul 2023.10.11 06:59:34
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Industries, Inc.

1070 Technology Dr.
N. Venice, FL 34275, USA

Certification ID:	190-1354
Company Code:	190
Certification Date:	10/11/2023
Revision:	0
Revision Date:	10/11/2023
Expiration Date:	10/11/2027

Product Rating Information:

Model:	CA5440 PVC Casement Window			
Operator Type:	C			
Configuration:	ALL/Snub, GS - 5/32" Ann IG			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-22			
Product Rating:	Class LC-PG35 1016x2134 (~40x84)-Type C			
Rated Dimensions:	Max Width:	40 in	Max Height:	84 in

Qualifying Test Information:

Test Report No:	NOK-0059
Test Report Expiration:	10/11/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standards. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of certification labels for the Keystone Fenestration Certification Program. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.



Authorized By:

Shaun Shaull
Shaun Shaull
2023.10.11 08:37:12
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500