



Impact Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-287
Company Code:	190
Certification Date:	12/23/2014
Revision No:	1
Revision Date:	10/18/2024
Expiration Date:	11/19/2027

Product Rating Information:

Model:	DH5560 PVC Impact Fin/Equal Leg Double Hung		
Operator Type:	H		
Configuration:	All, GS-5/16" Ann Lami IG		
Referenced Standard:	ASTM E1886-05/E1996-12		
Product Rating:	Missile Level D, Wind Zone 4, DP=+/-50, 52x86		
Rated Dimensions:	Max Width:	52 in	Max Height: 86 in
Linked Structural CARs:	190-1034.0		

Qualifying Test information:

Test Report No:	FTL-7981/7982
Test Report Expiration:	11/19/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.10.18
07:58:32 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	12/23/2014	Initial Issuance.
1	10/18/2024	Granted 3 Year Extension.



Impact Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-288
Company Code:	190
Certification Date:	12/23/2014
Revision No:	1
Revision Date:	10/18/2024
Expiration Date:	11/19/2027

Product Rating Information:

Model:	DH5560 PVC Impact Fin/Equal Leg Double Hung		
Operator Type:	H		
Configuration:	All, GS-5/16" Ann Lami IG		
Referenced Standard:	ASTM E1886-05/E1996-12		
Product Rating:	Missile Level D, Wind Zone 4, DP=+65/-70, 52x86		
Rated Dimensions:	Max Width:	52 in	Max Height: 86 in
Linked Structural CARs:	190-1035.0		

Qualifying Test information:

Test Report No:	FTL-7983/7984/8159
Test Report Expiration:	11/19/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaul
Shaun Shaul
2024.10.18
07:59:47 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	12/23/2014	Initial Issuance.
1	10/18/2024	Granted 3 Year Extension.



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-1034
Company Code:	190
Certification Date:	12/23/2014
Revision No:	2
Revision Date:	10/18/2024
Expiration Date:	11/19/2027

Product Rating Information:

Model:	DH5560 PVC Impact Equal Leg Double Hung		
Operator Type:	H		
Configuration:	All, GS-5/16" Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11		
Product Rating:	Class LC-PG50 1324x2192 (~52x86)-Type H, WTP=9.75		
Rated Dimensions:	Max Width:	52 in	Max Height: 86 in

Qualifying Test Information:

Test Report No:	FTL-7979
Test Report Expiration:	11/19/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.10.18 08:15:03
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	12/23/2014	Initial Issuance.
1	7/26/2023	Updated formatting of Rating for labeling purposes.
2	10/18/2024	Granted 3 Year Extension.



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-1035
Company Code:	190
Certification Date:	12/23/2014
Revision No:	1
Revision Date:	10/18/2024
Expiration Date:	11/19/2027

Product Rating Information:

Model:	DH5560 PVC Impact Equal Leg Double Hung		
Operator Type:	H		
Configuration:	All, GS-5/16" Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11		
Product Rating:	Class LC-PG65 1324x2192 (52x86)-Type H, Neg DP=70		
Rated Dimensions:	Max Width:	52 in	Max Height: 86 in

Qualifying Test Information:

Test Report No:	FTL-7980
Test Report Expiration:	11/19/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaul
Shaun Shaul 2024.10.18 08:16:01
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	12/23/2014	Initial Issuance.
1	10/18/2024	Granted 3 Year Extension.