



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

| | |
|---------------------|------------|
| Certification ID: | 190-1041 |
| Company Code: | 190 |
| Certification Date: | 1/7/2015 |
| Revision No: | 1 |
| Revision Date: | 12/4/2024 |
| Expiration Date: | 12/11/2027 |

Product Rating Information:

| | | | | |
|----------------------|--|-------|-------------|-------|
| Model: | HR5410 PVC Horizontal Slider XO | | | |
| Operator Type: | HS | | | |
| Configuration: | EM/All | | | |
| Referenced Standard: | AAMA/WDMA/CSA 101/IS2/A440-22 | | | |
| Product Rating: | Class LC-PG65 1905x1829 (75x72)-Type HS, Neg DP=70 | | | |
| Rated Dimensions: | Max Width: | 75 in | Max Height: | 72 in |

Qualifying Test Information:

| | |
|-------------------------|---------------|
| Test Report No: | FTL-8024/8026 |
| Test Report Expiration: | 12/11/2027 |

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.12.04 07:45:09
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

| | |
|---------------------|------------|
| Certification ID: | 190-1042 |
| Company Code: | 190 |
| Certification Date: | 1/7/2015 |
| Revision No: | 1 |
| Revision Date: | 12/4/2024 |
| Expiration Date: | 12/18/2027 |

Product Rating Information:

| | | | | |
|----------------------|---|-------|-------------|-------|
| Model: | HR5410 PVC Horizontal Slider XO | | | |
| Operator Type: | HS | | | |
| Configuration: | EM/All | | | |
| Referenced Standard: | AAMA/WDMA/CSA 101/IS2/A440-22 | | | |
| Product Rating: | Class LC-PG50 1905x1600 (75x63)-Type HS | | | |
| Rated Dimensions: | Max Width: | 75 in | Max Height: | 63 in |

Qualifying Test Information:

| | |
|-------------------------|------------|
| Test Report No: | FTL-8027 |
| Test Report Expiration: | 12/18/2027 |

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.12.04 07:50:33
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

| | |
|---------------------|------------|
| Certification ID: | 190-1043 |
| Company Code: | 190 |
| Certification Date: | 1/7/2015 |
| Revision No: | 1 |
| Revision Date: | 12/4/2024 |
| Expiration Date: | 12/16/2027 |

Product Rating Information:

| | | | | |
|----------------------|---|-------|-------------|-------|
| Model: | HR5410 PVC Horizontal Slider XO | | | |
| Operator Type: | HS | | | |
| Configuration: | EM/All | | | |
| Referenced Standard: | AAMA/WDMA/CSA 101/IS2/A440-22 | | | |
| Product Rating: | Class R-PG65 1905x1372 (75x54)-Type HS, Neg DP=70 | | | |
| Rated Dimensions: | Max Width: | 75 in | Max Height: | 54 in |

Qualifying Test Information:

| | |
|-------------------------|-------------------|
| Test Report No: | FTL-8029/FTL-8030 |
| Test Report Expiration: | 12/16/2027 |

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.12.04 07:56:19
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

| | |
|---------------------|------------|
| Certification ID: | 190-1044 |
| Company Code: | 190 |
| Certification Date: | 1/7/2015 |
| Revision No: | 1 |
| Revision Date: | 12/4/2024 |
| Expiration Date: | 12/18/2027 |

Product Rating Information:

| | | | | |
|----------------------|--|-------|-------------|-------|
| Model: | HR5410 PVC Horizontal Slider XO | | | |
| Operator Type: | HS | | | |
| Configuration: | EM/All | | | |
| Referenced Standard: | AAMA/WDMA/CSA 101/IS2/A440-22 | | | |
| Product Rating: | Class R-PG50 1905x1372 (75x54)-Type HS, WTP=9.75 | | | |
| Rated Dimensions: | Max Width: | 75 in | Max Height: | 54 in |

Qualifying Test Information:

| | |
|-------------------------|------------|
| Test Report No: | FTL-8030 |
| Test Report Expiration: | 12/18/2027 |

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.12.04 07:59:21
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

| | |
|---------------------|------------|
| Certification ID: | 190-1045 |
| Company Code: | 190 |
| Certification Date: | 1/7/2015 |
| Revision No: | 1 |
| Revision Date: | 12/4/2024 |
| Expiration Date: | 12/16/2027 |

Product Rating Information:

| | | | | |
|----------------------|--|--------|-------------|-------|
| Model: | HR5410 PVC 1/4-1/2-1/4 Horizontal Slider XOX | | | |
| Operator Type: | HS | | | |
| Configuration: | EM/All | | | |
| Referenced Standard: | AAMA/WDMA/CSA 101/IS2/A440-22 | | | |
| Product Rating: | Class LC-PG50 3048x1600 (120x63)-Type HS, WTP=9.75 | | | |
| Rated Dimensions: | Max Width: | 120 in | Max Height: | 63 in |

Qualifying Test Information:

| | |
|-------------------------|------------|
| Test Report No: | FTL-8033 |
| Test Report Expiration: | 12/16/2027 |

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull Shaun Shaull
2024.12.04 08:09:22
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

| | |
|---------------------|------------|
| Certification ID: | 190-1073 |
| Company Code: | 190 |
| Certification Date: | 1/20/2015 |
| Revision No: | 1 |
| Revision Date: | 12/4/2024 |
| Expiration Date: | 12/16/2027 |

Product Rating Information:

| | | | | |
|----------------------|---|--------|-------------|-------|
| Model: | HR5410 PVC 1/4-1/2-1/4 Horizontal Slider XOX | | | |
| Operator Type: | HS | | | |
| Configuration: | EM/All | | | |
| Referenced Standard: | AAMA/WDMA/CSA 101/IS2/A440-22 | | | |
| Product Rating: | Class LC-PG65 3048x1600 (120x63)-Type HS, Neg DP=70 | | | |
| Rated Dimensions: | Max Width: | 120 in | Max Height: | 63 in |

Qualifying Test Information:

| | |
|-------------------------|----------------------------|
| Test Report No: | FTL-8032/FTL-8033/FTL-8024 |
| Test Report Expiration: | 12/16/2027 |

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull Shaun Shaull
2024.12.04 09:08:02
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Industries, Inc.

1070 Technology Dr.
N. Venice, FL 34275, USA

| | |
|---------------------|------------|
| Certification ID: | 190-1351 |
| Company Code: | 190 |
| Certification Date: | 10/11/2023 |
| Revision: | 0 |
| Revision Date: | 10/11/2023 |
| Expiration Date: | 10/11/2027 |

Product Rating Information:

| | | | | |
|----------------------|--|-------|-------------|-------|
| Model: | HR5410 PVC XO Horizontal Sliding Window | | | |
| Operator Type: | HS | | | |
| Configuration: | ALL/EM, GS - 5/32" Ann IG (Fixed) | | | |
| Referenced Standard: | AAMA/WDMA/CSA 101/IS2/A440-22 | | | |
| Product Rating: | Class LC-PG35 1905x1829 (~75x72)-Type HS | | | |
| Rated Dimensions: | Max Width: | 75 in | Max Height: | 72 in |

Qualifying Test Information:

| | |
|-------------------------|------------|
| Test Report No: | NOK-0047 |
| Test Report Expiration: | 10/11/2027 |

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standards. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of certification labels for the Keystone Fenestration Certification Program. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.



Authorized By:

Shaun Shaull
Shaun Shaull
2023.10.11 07:08:42
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Industries, Inc.

1070 Technology Dr.
N. Venice, FL 34275, USA

| | |
|---------------------|------------|
| Certification ID: | 190-1352 |
| Company Code: | 190 |
| Certification Date: | 10/11/2023 |
| Revision: | 0 |
| Revision Date: | 10/11/2023 |
| Expiration Date: | 10/11/2027 |

Product Rating Information:

| | | | | |
|----------------------|--|--------|-------------|-------|
| Model: | HR5410 PVC XOX Horizontal Sliding Window | | | |
| Operator Type: | HS | | | |
| Configuration: | ALL/EM, GS - 5/32" Ann IG (Fixed), GS - 1/8" Ann IG (Sash) | | | |
| Referenced Standard: | AAMA/WDMA/CSA 101/IS2/A440-22 | | | |
| Product Rating: | Class LC-PG35 3048x1600* (~120x63*)-Type HS | | | |
| Rated Dimensions: | Max Width: | 120 in | Max Height: | 63 in |

Qualifying Test Information:

| | |
|-------------------------|------------|
| Test Report No: | NOK-0047 |
| Test Report Expiration: | 10/11/2027 |

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standards. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of certification labels for the Keystone Fenestration Certification Program. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.



Authorized By:

Shaun Shaull Shaun Shaull
2023.10.11 07:27:41
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500