



Impact Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-289
Company Code:	190
Certification Date:	1/8/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/11/2027

Product Rating Information:

Model:	HR5510 PVC Impact Horizontal Slider		
Operator Type:	HS		
Configuration:	EM/All/Clip, GS-5/16" Ann Lami IG		
Referenced Standard:	ASTM E1886-19/E1996-23		
Product Rating:	Missile Level D, Wind Zone 4, DP=+/-50, 75x72 XO		
Rated Dimensions:	Max Width:	75 in	Max Height: 72 in
Linked Structural CARs:	190-1046.0		

Qualifying Test information:

Test Report No:	FTL-8036/8037/8038/8133
Test Report Expiration:	12/11/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaul
Shaun Shaul
2024.12.04
12:41:08 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/8/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year due to standard equivalency.



Impact Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-291
Company Code:	190
Certification Date:	1/8/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/11/2027

Product Rating Information:

Model:	HR5510 PVC Impact Horizontal Slider		
Operator Type:	HS		
Configuration:	EM/All/Clip, GS-5/16" Ann Lami IG		
Referenced Standard:	ASTM E1886-19/E1996-23		
Product Rating:	Missile Level D, Wind Zone 4, DP=+65/-70, 75x63 XO		
Rated Dimensions:	Max Width:	75 in	Max Height: 63 in
Linked Structural CARs:	190-1047.0		

Qualifying Test information:

Test Report No:	FTL-8040/8041/8042
Test Report Expiration:	12/11/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.12.04
12:43:10 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/8/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year due to standard equivalency.



Impact Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-292
Company Code:	190
Certification Date:	1/8/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/16/2027

Product Rating Information:

Model:	HR5510 PVC Impact Horizontal Slider		
Operator Type:	HS		
Configuration:	EM/All/Clip, GS-5/16" Ann Lami IG		
Referenced Standard:	ASTM E1886-19/E1996-23		
Product Rating:	Missile Level D, Wind Zone 4, DP +/-50, 75x63 XO		
Rated Dimensions:	Max Width:	75 in	Max Height: 63 in
Linked Structural CARs:	190-1048.0		

Qualifying Test information:

Test Report No:	FTL-8044/8045/8046
Test Report Expiration:	12/16/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.12.04
12:45:47 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/8/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year due to standard equivalency.



Impact Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-296
Company Code:	190
Certification Date:	1/13/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/16/2027

Product Rating Information:

Model:	HR5510 PVC 1/4-1/2-1/4 Impact Horiz Slider		
Operator Type:	HS		
Configuration:	EM/All/Clip, GS-5/16" Ann Lami IG		
Referenced Standard:	ASTM E1886-19/E1996-23		
Product Rating:	Missile Level D, Wind Zone 4, DP=+65/-70, 120x63 XOX		
Rated Dimensions:	Max Width:	120 in	Max Height: 63 in
Linked Structural CARs:	190-1052.0		

Qualifying Test information:

Test Report No:	FTL-8050
Test Report Expiration:	12/16/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaul
Shaun Shaul 2024.12.04
12:48:11 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/13/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year due to standard equivalency.



Impact Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-298
Company Code:	190
Certification Date:	1/13/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/16/2027

Product Rating Information:

Model:	HR5510 PVC 1/4-1/2-1/4 Impact Horiz Slider		
Operator Type:	HS		
Configuration:	EM/All/Clip, GS-5/16" Ann Lami IG		
Referenced Standard:	ASTM E1886-19/E1996-23		
Product Rating:	Missile Level D, Wind Zone 4, DP=+/-50, 120x63 XOX		
Rated Dimensions:	Max Width:	120 in	Max Height: 63 in
Linked Structural CARs:	190-1054.0		

Qualifying Test information:

Test Report No:	FTL-8052/8053
Test Report Expiration:	12/16/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.12.04
12:52:47 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/13/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year due to standard equivalency.



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-1041
Company Code:	190
Certification Date:	1/7/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/11/2027

Product Rating Information:

Model:	HR5410 PVC Horizontal Slider XO		
Operator Type:	HS		
Configuration:	EM/All		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-22		
Product Rating:	Class LC-PG65 1905x1829 (75x72)-Type HS, Neg DP=70		
Rated Dimensions:	Max Width:	75 in	Max Height: 72 in

Qualifying Test Information:

Test Report No:	FTL-8024/8026
Test Report Expiration:	12/11/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.12.04 07:45:09
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/7/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year to 2022 due to standard equivalency.



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-1046
Company Code:	190
Certification Date:	1/8/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/11/2027

Product Rating Information:

Model:	HR5510 PVC Impact Horizontal Slider XO		
Operator Type:	HS		
Configuration:	EM/All, GS-5/16" Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-22		
Product Rating:	Class LC-PG50 1905x1829 (75x72)-Type HS, WTP=9.75		
Rated Dimensions:	Max Width:	75 in	Max Height: 72 in

Qualifying Test Information:

Test Report No:	FTL-8035/ FTL-8024
Test Report Expiration:	12/11/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull
2024.12.04
08:18:34 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/8/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year to 2022 due to standard equivalency.



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-1047
Company Code:	190
Certification Date:	1/8/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/11/2027

Product Rating Information:

Model:	HR5510 PVC Impact Horizontal Slider XO		
Operator Type:	HS		
Configuration:	EM/All, GS-5/16" Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-22		
Product Rating:	Class LC-PG65 1905x1600 (75x63)-Type HS, Neg DP=70		
Rated Dimensions:	Max Width:	75 in	Max Height: 63 in

Qualifying Test Information:

Test Report No:	FTL-8039/ FTL-8027
Test Report Expiration:	12/11/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
2024.12.04
08:21:40 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/8/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year to 2022 due to standard equivalency.



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-1048
Company Code:	190
Certification Date:	1/8/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/16/2027

Product Rating Information:

Model:	HR5510 PVC Impact Horizontal Slider XO		
Operator Type:	HS		
Configuration:	EM/All, GS-5/16" Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-22		
Product Rating:	Class LC-PG50 1905x1600 (75x63)-Type HS, WTP=9.75		
Rated Dimensions:	Max Width:	75 in	Max Height: 63 in

Qualifying Test Information:

Test Report No:	FTL-8043/FTL-8027
Test Report Expiration:	12/16/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaul
Shaun Shaul 2024.12.04 08:30:02
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/8/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year to 2022 due to standard equivalency.



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-1052
Company Code:	190
Certification Date:	1/12/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/16/2027

Product Rating Information:

Model:	HR5510 PVC 1/4-1/2-1/4 Impact Horiz Slider XOX		
Operator Type:	HS		
Configuration:	EM/All, GS-5/16" Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-22		
Product Rating:	Class LC-PG65 3048x1600 (120x63)-Type HS, Neg DP=70		
Rated Dimensions:	Max Width:	120 in	Max Height: 63 in

Qualifying Test Information:

Test Report No:	FTL-8049/ FTL-8033
Test Report Expiration:	12/16/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull
2024.12.04
08:38:13 -05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/12/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year to 2022 due to standard equivalency.



Structural Performance Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-1054
Company Code:	190
Certification Date:	1/13/2015
Revision No:	1
Revision Date:	12/4/2024
Expiration Date:	12/16/2027

Product Rating Information:

Model:	HR5510 PVC 1/4-1/2-1/4 Impact Horiz Slider XOX		
Operator Type:	HS		
Configuration:	EM/All, GS-5/16" Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-22		
Product Rating:	Class LC-PG50 3048x1600 (120x63)-Type HS, WTP=9.75		
Rated Dimensions:	Max Width:	120 in	Max Height: 63 in

Qualifying Test Information:

Test Report No:	FTL-8051/FTL-8033
Test Report Expiration:	12/16/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.12.04 08:41:23
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	1/13/2015	Initial issuance.
1	12/4/2024	Granted 3 year extension. Updated reference standard year to 2022 due to standard equivalency.