



Structural Performance Certification Authorization Report

PGT Industries, Inc.

1070 Technology Dr.
N. Venice, FL 34275, USA

Certification ID:	190-770
Company Code:	190
Certification Date:	12/13/2010
Revision No:	2
Revision Date:	10/20/2023
Expiration Date:	11/11/2026

Product Rating Information:

Model:	5470/5570 Sliding Glass Door w & w/o Corner			
Operator Type:	SD			
Configuration:	H/J/S/Ast/Clip/All/3-1/2SR, GS-3/16 Temp IG			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11			
Product Rating:	Class LC-PG60 2515x5144x2438 (~99x203x96)-Type SD			
Rated Dimensions:	Max Width:	203 in	Max Height:	96 in

Qualifying Test Information:

Test Report No:	FTL-6367/6368/8545
Test Report Expiration:	11/11/2026

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull
2023.10.20
07:04:03 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Industries, Inc.

1070 Technology Dr.
N. Venice, FL 34275, USA

Certification ID:	190-771
Company Code:	190
Certification Date:	12/13/2010
Revision No:	1
Revision Date:	10/20/2023
Expiration Date:	11/21/2026

Product Rating Information:

Model:	5470 Sliding Glass Door w & w/o Corner			
Operator Type:	SD			
Configuration:	H/J/S/Clip/All/3-1/2SR, GS-3/16 Temp IG			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11			
Product Rating:	Class LC-PG60 3108x6309x2438 (122x248x96)-Type SD			
Rated Dimensions:	Max Width:	248 in	Max Height:	96 in

Qualifying Test Information:

Test Report No:	FTL-6370/8539/8544
Test Report Expiration:	11/21/2026

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull
2023.10.20 07:08:17
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Industries, Inc.

1070 Technology Dr.
N. Venice, FL 34275, USA

Certification ID:	190-772
Company Code:	190
Certification Date:	12/13/2010
Revision No:	1
Revision Date:	10/20/2023
Expiration Date:	11/15/2026

Product Rating Information:

Model:	5470 Sliding Glass Door w & w/o Corner			
Operator Type:	SD			
Configuration:	H/J/S/Ast/Clip/All/4-1/16SR, GS-3/16 Temp IG			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11			
Product Rating:	Class LC-PG80 5144x2438 (99x203x96)-Type SD			
Rated Dimensions:	Max Width:	203 in	Max Height:	96 in

Qualifying Test Information:

Test Report No:	FTL-6369/8539/8544
Test Report Expiration:	11/15/2026

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2023.10.20 07:10:45
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

PGT Industries, Inc.

1070 Technology Dr.
N. Venice, FL 34275, USA

Certification ID:	190-774
Company Code:	190
Certification Date:	12/15/2010
Revision No:	2
Revision Date:	10/20/2023
Expiration Date:	11/23/2026

Product Rating Information:

Model:	5470 Sliding Glass Door w & w/o Corner			
Operator Type:	SD			
Configuration:	H/J/S/Ast/Clip/All/3-1/2SR, GS-3/16" Temp IG			
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11			
Product Rating:	Class LC-PG60 2515x5144x3048 (~99x203x120)-Type SD, Neg DP=65			
Rated Dimensions:	Max Width:	203 in	Max Height:	120 in

Qualifying Test Information:

Test Report No:	FTL-6371/8539/8544
Test Report Expiration:	11/23/2026

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2023.10.20
07:16:50 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500