



Impact Performance Certification Authorization Report

PGT Industries LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-285
Company Code:	190
Certification Date:	11/11/2014
Revision No:	1
Revision Date:	9/19/2024
Expiration Date:	10/1/2027

Product Rating Information:

Model:	SH5500 View PVC Imp Single Hung		
Operator Type:	H		
Configuration:	EM/All, GS-5/16" Ann Lami IG		
Referenced Standard:	ASTM E1886-05/E1996-12		
Product Rating:	Missile Level D, Wind Zone 4, DP=+/-50, 52x92		
Rated Dimensions:	Max Width:	52 in	Max Height: 92 in
Linked Structural CARs:	190-1028.0		

Qualifying Test information:

Test Report No:	FTL-7951/7952/7953
Test Report Expiration:	10/1/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull
2024.09.19
08:52:43 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	11/11/2014	Initial Issuance.
1	9/19/2024	Granted 3 Year Extension.



Impact Performance Certification Authorization Report

PGT Industries LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-286
Company Code:	190
Certification Date:	11/17/2014
Revision No:	1
Revision Date:	9/19/2024
Expiration Date:	10/6/2027

Product Rating Information:

Model:	SH5500 View PVC Imp Single Hung		
Operator Type:	H		
Configuration:	EM/All, GS-5/16" Ann Lami IG		
Referenced Standard:	ASTM E1886-05/E1996-12		
Product Rating:	Missile Level D, Wind Zone 4, DP=+65/-70, 52x92		
Rated Dimensions:	Max Width:	52 in	Max Height: 92 in
Linked Structural CARs:	190-1029.0		

Qualifying Test information:

Test Report No:	FTL-7954/7955/7956
Test Report Expiration:	10/6/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull
2024.09.19
08:53:29 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	11/17/2014	Initial Issuance.
1	9/19/2024	Granted 3 Year Extension.



Structural Performance Certification Authorization Report

PGT Industries LLC

3400 Precision Dr

N. Venice, FL 34275, USA

Certification ID:	190-1028
Company Code:	190
Certification Date:	11/11/2014
Revision No:	1
Revision Date:	9/19/2024
Expiration Date:	10/2/2027

Product Rating Information:

Model:	SH5500 View PVC Imp Single Hung		
Operator Type:	H		
Configuration:	EM/All, GS-5/16" Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11		
Product Rating:	Class LC-PG50 1324x2330 (52x92)-Type H		
Rated Dimensions:	Max Width:	52 in	Max Height: 92 in

Qualifying Test Information:

Test Report No:	FTL-7949
Test Report Expiration:	10/2/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.09.19 09:01:25
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	11/11/2014	Initial Issuance.
1	9/19/2024	Granted 3 Year Extension.



Structural Performance Certification Authorization Report

PGT Industries LLC

3400 Precision Dr
N. Venice, FL 34275, USA

Certification ID:	190-1029
Company Code:	190
Certification Date:	11/11/2014
Revision No:	1
Revision Date:	9/19/2024
Expiration Date:	10/1/2027

Product Rating Information:

Model:	SH5500 View PVC Imp Single Hung		
Operator Type:	H		
Configuration:	EM/All, GS-5/16" Ann Lami IG		
Referenced Standard:	AAMA/WDMA/CSA 101/IS2/A440-11		
Product Rating:	Class LC-PG65 1324x2330 (52x92)-Type H, Neg DP=70		
Rated Dimensions:	Max Width:	52 in	Max Height: 92 in

Qualifying Test Information:

Test Report No:	FTL-7950
Test Report Expiration:	10/1/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.09.19 09:02:06
-04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	11/11/2014	Initial Issuance.
1	9/19/2024	Granted 3 Year Extension.