Impact Performance
Certification Authorization Report

PGT Custom Windows and Doors, LLC

3400 Precision Dr
N. Venice, FL 34275, USA

Certification ID:	190-584
Company Code:	190
Certification Date:	3/28/2025
Revision No:	0
Revision Date:	3/28/2025
Expiration Date:	3/28/2029

Product Rating Information:

Model:	5570NS Sliding Glass Door XXX (2-1/2" riser)			
Operator Type:	SD			
Configuration:	TR/BR/LS/EM/IM/SR, GS - 1/2" HS Lami IG			
Referenced Standard:	ASTM E1886-19, ASTM E1996-23			
Product Rating:	Missile Level D, Wind Zone 3, DP +35/-60, ~152x98			
Rated Dimensions:	**Max Width:**	152 in	**Max Height:**	98 in
Linked Structural CARs:	190-1361			

Qualifying Test information:

Test Report No:	NOK-0074, NOK-0106aR1
Test Report Expiration:	3/28/2029

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com

Authorized By: Shaun Shaull 2025.03.28 12:51:47 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500

Revision History

Rev #	Date	Description
0	3/28/2025	Initial issuance.